CALHOUN COUNTY MIDDLE/HIGH SCHOOL

One of the two filter beds is non-operational.

Filter bed that operates has misaligned walls.

Leaking joints at filter bed corners.

Filter bed in use drains wastewater poorly, resulting in operational failures.